



REDACTED VERSION

SCOTT THOMPSON  
EXECUTIVE DIRECTOR

OKLAHOMA DEPARTMENT OF ENVIRONMENTAL QUALITY

MARY FALLIN  
GOVERNOR

September 18, 2014

(b) (6)

Dear Mr. and Mrs. (b) (6) :

The Oklahoma Department of Environmental Quality (DEQ) sampled water from your house well on August 20, 2014 to specifically test for lead. Previous sample results from sampling performed in June 2014 indicated an exceedance for lead at 25.5 ug/l, which is above the Maximum Contaminant Level (MCL) of 15 ug/l for drinking water.

Lead was detected below the MCL in two water samples collected in August 2014. Results of the sampling are included with this letter.

If you have questions about this letter or the sampling data, do not hesitate to call me at (405) 702-5136. Please contact Bart Canellas with the U.S. Environmental Protection Agency at (214) 665-6662 with any questions about the EPA Superfund process or plans for the Wilcox Site.

Sincerely,

Todd Downham  
Project Manager, Wilcox Oil Company Superfund Site  
Land Protection Division  
Oklahoma Department of Environmental Quality

c. Bart Canellas, U.S. EPA Dallas

Sample Number: 539574  
Project Code: SW-X  
Agency Number:  
Date Collected: 8/20/2014  
Time Collected: 1315  
Date Received: 8/20/2014  
Date Completed: 08/26/2014  
Collected By: TD  
PWS Id:  
Location Code:  
Station:  
Facility:  
Report Date: 8/26/2014

OKLAHOMA DEPARTMENT OF ENVIRONMENTAL QUALITY  
STATE ENVIRONMENTAL LABORATORY  
707 N. ROBINSON  
OKLAHOMA CITY  
OKLAHOMA, 73102-6010  
General Inquiries: 1-866-412-3057  
or selsd@deq.ok.gov

**Report of Analysis by Metals**  
EPA Drinking Water Certification #OK00013

To: TODD DOWNHAM/LPD

CC:

Name	Qualifier	Value	Units	Analyzed	Method	Prep Type
Lead, Total		7.20	UG/L	08/21/14	200.8	

Summary

Labs performing analysis on this Sample:

Metals

SOURCE: WILCOX

SAMPLERS COMMENTS:

WR-1L

ANALYST'S COMMENTS:

*Greg Goode*

Greg Goode  
State Environmental Laboratory

\*

\* ANALYST

Sample Number: 539575  
Project Code: SW-X  
Agency Number:  
Date Collected: 8/20/2014  
Time Collected: 1315  
Date Received: 8/20/2014  
Date Completed: 08/26/2014  
Collected By: TD  
PWS Id:  
Location Code:  
Station:  
Facility:  
Report Date: 8/26/2014

**OKLAHOMA DEPARTMENT OF ENVIRONMENTAL QUALITY**  
**STATE ENVIRONMENTAL LABORATORY**  
707 N. ROBINSON  
OKLAHOMA CITY  
OKLAHOMA, 73102-6010  
General Inquiries: 1-866-412-3057  
or selsd@deq.ok.gov  
**Report of Analysis by Metals**  
EPA Drinking Water Certification #OK00013

To: TODD DOWNHAM/LPD

CC:

Name	Qualifier	Value	Units	Analyzed	Method	Prep Type
Lead, Total		7.00	UG/L	08/21/14	200.8	

**Summary**

Labs performing analysis on this Sample:

Metals

SOURCE: WILCOX

SAMPLERS COMMENTS:  
WR-11L

ANALYST'S COMMENTS:

*Greg Goode*

\*

\* ANALYST

\_\_\_\_\_  
Greg Goode  
State Environmental Laboratory